



## PSHB 80-90-100L - Peak Series High Bay

**PSHB 80-90-100L PERFORMANCE TABLE**

Catalog Number	Delivered Lumens	Lumens Down	% Lumens Down	Lumens Up	% Lumens Up	Watts	Efficiency	Max UGR
PSHB-4-80L-CAC-D-UNV-835	82,888	82,615	99.67%	273	0.33%	424	195	32
PSHB-4-80L-CAC-D-UNV-840	82,576	82,304	99.67%	272	0.33%	424	195	32
PSHB-4-80L-CAC-D-UNV-850	84,249	83,971	99.67%	278	0.33%	424	199	32
PSHB-4-80L-CAC-I-UNV-835	72,364	2,761	3.82%	69,603	96.18%	424	171	20
PSHB-4-80L-CAC-I-UNV-840	72,092	2,751	3.82%	69,342	96.19%	424	170	20
PSHB-4-80L-CAC-I-UNV-850	73,552	2,806	3.81%	70,746	96.19%	424	173	20
PSHB-4-80L-CAD-D-UNV-835	76,977	74,490	96.77%	2,486	3.23%	424	182	36
PSHB-4-80L-CAD-D-UNV-840	76,687	74,210	96.77%	2,477	3.23%	424	181	36
PSHB-4-80L-CAD-D-UNV-850	78,241	75,714	96.77%	2,527	3.23%	424	185	36
PSHB-4-80L-CAD-I-UNV-835	67,259	4,955	7.37%	62,304	92.63%	424	159	26
PSHB-4-80L-CAD-I-UNV-840	67,005	4,936	7.37%	62,069	92.63%	424	158	26
PSHB-4-80L-CAD-I-UNV-850	68,363	5,036	7.37%	63,327	92.63%	424	161	27
PSHB-4-80L-FAC-D-UNV-835	81,021	79,869	98.58%	1,151	1.42%	424	191	33
PSHB-4-80L-FAC-D-UNV-840	80,717	79,569	98.58%	1,147	1.42%	424	190	33
PSHB-4-80L-FAC-D-UNV-850	82,352	81,181	98.58%	1,171	1.42%	424	194	33
PSHB-4-80L-FAC-I-UNV-835	80,741	1,763	2.18%	78,978	97.82%	424	190	16
PSHB-4-80L-FAC-I-UNV-840	80,438	1,757	2.18%	78,681	97.82%	424	190	16
PSHB-4-80L-FAC-I-UNV-850	82,066	1,792	2.18%	80,274	97.82%	424	194	16
PSHB-4-80L-FAD-D-UNV-835	75,244	72,567	96.44%	2,678	3.56%	424	177	34
PSHB-4-80L-FAD-D-UNV-840	74,962	72,294	96.44%	2,668	3.56%	424	177	34
PSHB-4-80L-FAD-D-UNV-850	76,481	73,758	96.44%	2,723	3.56%	424	180	34
PSHB-4-80L-FAD-I-UNV-835	74,582	3,233	4.33%	71,350	95.67%	424	176	21
PSHB-4-80L-FAD-I-UNV-840	74,303	3,221	4.33%	71,082	95.67%	424	175	21
PSHB-4-80L-FAD-I-UNV-850	75,808	3,286	4.33%	72,522	95.67%	424	179	21
PSHB-4-80L-FPC-D-UNV-835	81,490	80,600	98.91%	891	1.09%	424	192	32
PSHB-4-80L-FPC-D-UNV-840	81,185	80,297	98.91%	888	1.09%	424	191	32
PSHB-4-80L-FPC-D-UNV-850	82,829	81,923	98.91%	906	1.09%	424	195	32
PSHB-4-80L-FPC-I-UNV-835	70,932	3,277	4.62%	67,655	95.38%	424	167	22
PSHB-4-80L-FPC-I-UNV-840	70,666	3,264	4.62%	67,402	95.38%	424	167	22
PSHB-4-80L-FPC-I-UNV-850	72,097	3,330	4.62%	68,767	95.38%	424	170	22
PSHB-4-80L-FPD-D-UNV-835	69,492	67,166	96.65%	2,327	3.35%	424	164	34
PSHB-4-80L-FPD-D-UNV-840	69,231	66,913	96.65%	2,318	3.35%	424	163	34
PSHB-4-80L-FPD-D-UNV-850	70,634	68,268	96.65%	2,365	3.35%	424	167	34
PSHB-4-80L-FPD-I-UNV-835	62,934	4,576	7.27%	58,358	92.73%	424	148	24
PSHB-4-80L-FPD-I-UNV-840	62,698	4,559	7.27%	58,139	92.73%	424	148	24
PSHB-4-80L-FPD-I-UNV-850	63,968	4,651	7.27%	59,317	92.73%	424	151	24
PSHB-4-80L-LL-D-UNV-835	84,119	83,935	99.78%	184	0.22%	424	198	33
PSHB-4-80L-LL-D-UNV-840	83,803	83,620	99.78%	184	0.22%	424	198	33
PSHB-4-80L-LL-D-UNV-850	85,500	85,314	99.78%	186	0.22%	424	202	33
PSHB-4-80L-NAC-D-UNV-835	80,935	79,679	98.45%	1,256	1.55%	424	191	31
PSHB-4-80L-NAC-D-UNV-840	80,631	79,379	98.45%	1,252	1.55%	424	190	31
PSHB-4-80L-NAC-D-UNV-850	82,264	80,987	98.45%	1,277	1.55%	424	194	31
PSHB-4-80L-NAC-I-UNV-835	79,779	2,124	2.66%	77,654	97.34%	424	188	18
PSHB-4-80L-NAC-I-UNV-840	79,479	2,116	2.66%	77,362	97.34%	424	187	18
PSHB-4-80L-NAC-I-UNV-850	81,089	2,159	2.66%	78,930	97.34%	424	191	18
PSHB-4-90L-CAC-D-UNV-835	92,765	92,459	99.67%	305	0.33%	479	194	33
PSHB-4-90L-CAC-D-UNV-840	92,416	92,112	99.67%	304	0.33%	479	193	33
PSHB-4-90L-CAC-D-UNV-850	94,289	93,978	99.67%	310	0.33%	479	197	33
PSHB-4-90L-CAC-I-UNV-835	80,988	3,090	3.82%	77,897	96.18%	479	169	21
PSHB-4-90L-CAC-I-UNV-840	80,684	3,079	3.82%	77,605	96.18%	479	168	21
PSHB-4-90L-CAC-I-UNV-850	82,317	3,140	3.81%	79,177	96.19%	479	172	21
PSHB-4-90L-CAD-D-UNV-835	86,150	83,367	96.77%	2,783	3.23%	479	180	37
PSHB-4-90L-CAD-D-UNV-840	85,826	83,054	96.77%	2,772	3.23%	479	179	37
PSHB-4-90L-CAD-D-UNV-850	87,565	84,736	96.77%	2,828	3.23%	479	183	37
PSHB-4-90L-CAD-I-UNV-835	75,273	5,545	7.37%	69,728	92.63%	479	157	27
PSHB-4-90L-CAD-I-UNV-840	74,990	5,524	7.37%	69,466	92.63%	479	157	27
PSHB-4-90L-CAD-I-UNV-850	76,509	5,636	7.37%	70,874	92.63%	479	160	27
PSHB-4-90L-FAC-D-UNV-835	90,676	89,387	98.58%	1,289	1.42%	479	189	33
PSHB-4-90L-FAC-D-UNV-840	90,336	89,051	98.58%	1,284	1.42%	479	189	33
PSHB-4-90L-FAC-D-UNV-850	92,166	90,855	98.58%	1,311	1.42%	479	192	33
PSHB-4-90L-FAC-I-UNV-835	90,364	1,974	2.18%	88,390	97.82%	479	189	17
PSHB-4-90L-FAC-I-UNV-840	90,023	1,966	2.18%	88,057	97.82%	479	188	17
PSHB-4-90L-FAC-I-UNV-850	91,846	2,005	2.18%	89,841	97.82%	479	192	17
PSHB-4-90L-FAD-D-UNV-835	84,212	81,214	96.44%	2,998	3.56%	479	176	35
PSHB-4-90L-FAD-D-UNV-840	83,895	80,909	96.44%	2,986	3.56%	479	175	35
PSHB-4-90L-FAD-D-UNV-850	85,594	82,547	96.44%	3,047	3.56%	479	179	35
PSHB-4-90L-FAD-I-UNV-835	83,470	3,618	4.33%	79,852	95.67%	479	174	22
PSHB-4-90L-FAD-I-UNV-840	83,157	3,605	4.34%	79,553	95.67%	479	174	22

