


itl boulder
THE LIGHT CENTER OF THE INDUSTRY SINCE 1955

INDEPENDENT TESTING LABORATORIES, INC.
3386 LONGHORN ROAD, BOULDER, CO 80302 USA

PHONE: (303)442-1255 • FAX: (303)449-5274 • E-MAIL: itl@itlboulder.com • WEBSITE: www.itlboulder.com

ISOFOOTCANDLE LINES OF HORIZONTAL ILLUMINATION

Values based on 20 foot mounting height.



REPORT NUMBER: ITL65547

ISSUE DATE: 03/25/11 PAGE: 1 OF 6

DATE SAMPLE TESTED: 07/27/10

PREPARED FOR: LSI INDUSTRIES, INC.

CATALOG NUMBER: XAS3/XRS3/XAWS3/XENM3

SA/XINM3 SA 2 LED 63 450 CW UE

LUMINAIRE: FABRICATED BROWN PAINTED METAL HOUSING, 7 ROWS OF 9 LEDS, FABRICATED PREMIUM SPECULAR METAL REFLECTOR WITH 4 "V" SHAPED INSERTS BELOW 36 LEDS, CLEAR FLAT GLASS LENS IN FABRICATED BROWN PAINTED METAL LENS FRAME.

LAMPS: SIXTY-THREE WHITE LIGHT EMITTING DIODES (LEDs) EACH WITH CLEAR SEMI-HEMISPHERICAL INTEGRAL LENS, VERTICAL BASE-UP POSITION.

LED DRIVER: LED ELECTRONIC 450mA DRIVER
NOTE: DATA SHOWN IS ABSOLUTE FOR THE SAMPLE PROVIDED AT RATED INPUT VOLTAGE (120VAC, 60Hz) TO THE LED DRIVER. LED DRIVER INFORMATION PROVIDED BY CLIENT.

TOTAL INPUT WATTS = 97.8 AT 120.0 VOLTS


TEST PROCEDURE: IESNA LM-79-08


TEST DISTANCE = 33.25 FEET

IES Cutoff Classification: Full Cutoff

Checked *N. WHITE*

Approved *R. BEATTIE*
Lighting Engineer





itl boulder

THE LIGHT CENTER OF THE INDUSTRY SINCE 1955

INDEPENDENT TESTING LABORATORIES, INC.

3386 LONGHORN ROAD, BOULDER, CO 80302 USA

PHONE: (303)442-1255 • FAX: (303)449-5274 • E-MAIL: itl@itlboulder.com • WEBSITE: www.itlboulder.com

REPORT NUMBER: ITL65547

ISSUE DATE: 03/25/11 PAGE: 2 OF 6

DATE SAMPLE TESTED: 07/27/10

PREPARED FOR: LSI INDUSTRIES, INC.

CATALOG NUMBER: XAS3/XRS3/XAWS3/XENM3

SA/XINM3 SA 2 LED 63 450 CW UE

LUMINAIRE: FABRICATED BROWN PAINTED METAL HOUSING, 7 ROWS OF 9 LEDS, FABRICATED PREMIUM SPECULAR METAL REFLECTOR WITH 4 "V" SHAPED INSERTS BELOW 36 LEDS, CLEAR FLAT GLASS LENS IN FABRICATED BROWN PAINTED METAL LENS FRAME.

LAMPS: SIXTY-THREE WHITE LIGHT EMITTING DIODES (LEDs) EACH WITH CLEAR SEMI-HEMISPHERICAL INTEGRAL LENS, VERTICAL BASE-UP POSITION.

LED DRIVER: LED ELECTRONIC 450mA DRIVER


NOTE: DATA SHOWN IS ABSOLUTE FOR THE SAMPLE PROVIDED AT RATED INPUT VOLTAGE (120VAC, 60Hz) TO THE LED DRIVER. LED DRIVER INFORMATION PROVIDED BY CLIENT.

TOTAL INPUT WATTS = 97.8 AT 120.0 VOLTS

TEST PROCEDURE: IESNA LM-79-08

TEST DISTANCE = 33.25 FEET

MAXIMUM PLANE AND MAXIMUM CONE PLOTS OF CANDELA






REPORT NUMBER: ITL65547
ISSUE DATE: 03/25/11
PREPARED FOR: LSI INDUSTRIES, INC.

PAGE: 3 OF 6
DATE SAMPLE TESTED: 07/27/10

COEFFICIENTS OF UTILIZATION AND FLUX DISTRIBUTION



	LUMENS	PERCENT OF FIXTURE
DOWNWARD STREET SIDE	4400	69.5
DOWNWARD HOUSE SIDE	1934	30.5
DOWNWARD TOTAL	6334	100.0
UPWARD STREET SIDE	0	0.0
UPWARD HOUSE SIDE	0	0.0
UPWARD TOTAL	0	0.0
TOTAL FLUX	6334	100.0
EFFICACY = 64.8 Lm/W		

ALL CANDELA AND LUMENS IN THIS REPORT ARE BASED ON ABSOLUTE PHOTOMETRY.
THE COEFFICIENT OF UTILIZATION VALUES ARE BASED ON THE TOTAL ABSOLUTE
LUMEN OUTPUT OF THIS LUMINAIRE SAMPLE.



itl boulder
THE LIGHT CENTER OF THE INDUSTRY SINCE 1955

INDEPENDENT TESTING LABORATORIES, INC.
3386 LONGHORN ROAD, BOULDER, CO 80302 USA

PHONE: (303)442-1255 • FAX: (303)449-5274 • E-MAIL: itl@itlboulder.com • WEBSITE: www.itlboulder.com

REPORT NUMBER: ITL65547
ISSUE DATE: 03/25/11
PREPARED FOR: LSI INDUSTRIES, INC.

PAGE: 4 OF 6
DATE SAMPLE TESTED: 07/27/10


FLUX DISTRIBUTION BY SOLID ANGLE

(PER IESNA TM-15-07, LUMINAIRE CLASSIFICATION
SYSTEM FOR OUTDOOR LUMINAIRES)

	LUMENS	PERCENT OF FIXTURE	BUG ZONE RATINGS
FORWARD LIGHT	4400.	69.5	
FL (0- 30)	680.8	10.7	
FM (30- 60)	2610.4	41.2	
FH (60- 80)	1101.4	17.4	G1
FVH(80- 90)	7.7	0.1	U0 G0
BACK LIGHT	1934.	30.5	
BL (0- 30)	394.3	6.2	B1
BM (30- 60)	1143.4	18.1	B2
BH (60- 80)	391.3	6.2	B1 G1
BVH(80- 90)	5.1	0.1	U0 G0
UPLIGHT	0.	0.0	
UL (90-100)	0.0	0.0	U0
UH (100-180)	0.0	0.0	U0
TRAPPED LIGHT	0.	0.0	
TOTAL FLUX	6334.	100.0	

BACKLIGHT, UPLIGHT, AND GLARE (BUG) RATINGS
(PER ADDENDUM A FOR IESNA TM-15-07)

BUG RATING: B2 U0 G1



itl boulder
THE LIGHT CENTER OF THE INDUSTRY SINCE 1955

INDEPENDENT TESTING LABORATORIES, INC.
3386 LONGHORN ROAD, BOULDER, CO 80302 USA


PHONE: (303)442-1255 • FAX: (303)449-5274 • E-MAIL: itl@itlboulder.com • WEBSITE: www.itlboulder.com

REPORT NUMBER: ITL65547
ISSUE DATE: 03/25/11
PREPARED FOR: LSI INDUSTRIES, INC.

PAGE: 5 OF 6
DATE SAMPLE TESTED: 07/27/10

CANDELA TABULATION

	STREET SIDE										
	0.0	5.0	15.0	25.0	35.0	45.0	55.0	65.0	75.0	85.0	90.0
	90.0	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
	87.5	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.
	85.0	0.	0.	0.	0.	0.	2.	2.	3.	5.	6.
	82.5	3.	3.	5.	8.	11.	9.	11.	29.	46.	55.
	80.0	6.	6.	9.	15.	31.	31.	35.	83.	175.	218.
	77.5	9.	9.	14.	34.	118.	164.	100.	350.	558.	538.
	75.0	9.	11.	23.	101.	321.	287.	404.	742.	1104.	902.
	72.5	12.	15.	34.	91.	409.	636.	714.	1296.	1730.	1260.
	70.0	15.	20.	55.	198.	720.	1114.	1696.	1992.	2189.	1685.
	67.5	61.	81.	250.	393.	1077.	1971.	2283.	2842.	2702.	1929.
	65.0	129.	144.	381.	555.	1479.	2429.	2677.	3158.	2963.	2137.
	62.5	215.	223.	505.	1232.	1915.	2553.	3103.	3244.	3077.	2306.
	60.0	516.	541.	845.	1739.	1989.	2547.	3382.	3290.	3536.	2581.
	57.5	774.	793.	1158.	1876.	2104.	2527.	3462.	3364.	3651.	2803.
V	55.0	860.	872.	1221.	1782.	2181.	2634.	3293.	3455.	3581.	2805.
E	52.5	937.	943.	1120.	1481.	2197.	2713.	3068.	3516.	3439.	2705.
R	50.0	980.	986.	1046.	1318.	2181.	2710.	2940.	3518.	3200.	2501.
T	47.5	1014.	1028.	1078.	1269.	2037.	2653.	2955.	3613.	3046.	2324.
I	45.0<<	1088.	1109.	1161.	1312.	1871.	2536.	3186.	3731.	3138.	2309.
C	43.0	1149.	1167.	1198.	1335.	1731.	2416.	3358.	3717.	3249.	2424.
A	42.5	1161.	1174.	1201.	1332.	1700.	2396.	3378.	3708.	3247.	2453.
L	40.0	1207.	1218.	1223.	1306.	1573.	2327.	3392.	3570.	3270.	2561.
	37.5	1257.	1252.	1260.	1321.	1565.	2362.	3206.	3344.	3256.	2568.
A	35.0	1318.	1326.	1332.	1398.	1737.	2384.	3009.	3029.	3077.	2470.
N	32.5	1416.	1415.	1459.	1550.	1888.	2336.	2783.	2733.	2700.	2218.
G	30.0	1524.	1553.	1630.	1687.	1866.	2315.	2381.	2585.	2335.	1897.
L	27.5	1674.	1702.	1750.	1771.	1831.	2054.	2137.	2217.	2043.	1656.
E	25.0	1730.	1734.	1742.	1768.	1802.	1806.	1962.	2025.	1831.	1490.
	22.5	1708.	1716.	1736.	1757.	1728.	1644.	1690.	1849.	1751.	1461.
	20.0	1622.	1619.	1679.	1704.	1693.	1639.	1530.	1521.	1541.	1386.
	17.5	1564.	1567.	1607.	1610.	1604.	1593.	1518.	1373.	1344.	1238.
	15.0	1505.	1505.	1502.	1504.	1493.	1528.	1461.	1324.	1273.	1186.
	12.5	1444.	1450.	1441.	1421.	1415.	1421.	1369.	1281.	1250.	1174.
	10.0	1373.	1359.	1359.	1339.	1350.	1326.	1283.	1221.	1194.	1126.
	7.5	1266.	1275.	1270.	1270.	1264.	1253.	1220.	1180.	1138.	1094.
	5.0	1229.	1217.	1213.	1204.	1204.	1177.	1163.	1131.	1111.	1078.
	2.5	1140.	1134.	1137.	1127.	1121.	1117.	1108.	1100.	1088.	1064.
	0.0	1058.	1058.	1058.	1058.	1058.	1058.	1058.	1058.	1058.	1058.
								PLANE OF MAXIMUM CANDELA			
								CONE OF MAXIMUM CANDELA			



itl boulder
THE LIGHT CENTER OF THE INDUSTRY SINCE 1955

INDEPENDENT TESTING LABORATORIES, INC.
3386 LONGHORN ROAD, BOULDER, CO 80302 USA

PHONE: (303)442-1255 • FAX: (303)449-5274 • E-MAIL: itl@itlboulder.com • WEBSITE: www.itlboulder.com

REPORT NUMBER: ITL65547
ISSUE DATE: 03/25/11
PREPARED FOR: LSI INDUSTRIES, INC.

PAGE: 6 OF 6
DATE SAMPLE TESTED: 07/27/10

CANDELA TABULATION

	HOUSE SIDE	LATERAL ANGLE								
		95.0	105.0	115.0	125.0	135.0	145.0	155.0	165.0	175.0 180.0
	90.0	0.	0.	0.	0.	0.	0.	0.	0.	0.
	87.5	0.	0.	0.	0.	0.	0.	0.	0.	0.
	85.0	6.	3.	3.	2.	2.	0.	0.	0.	0.
	82.5	46.	18.	17.	14.	11.	14.	6.	5.	3. 3.
	80.0	123.	45.	41.	35.	25.	54.	20.	20.	6. 3.
	77.5	320.	141.	112.	45.	34.	147.	54.	41.	15. 12.
	75.0	568.	324.	200.	88.	45.	143.	66.	35.	22. 18.
	72.5	856.	654.	350.	137.	68.	89.	91.	91.	23. 28.
	70.0	1192.	1077.	422.	163.	83.	103.	117.	296.	45. 52.
	67.5	1459.	1339.	647.	220.	124.	124.	101.	232.	63. 74.
	65.0	1650.	1544.	1127.	301.	218.	166.	98.	141.	66. 68.
	62.5	1846.	1743.	1545.	442.	212.	175.	115.	95.	66. 61.
	60.0	1985.	1900.	1774.	673.	204.	169.	217.	106.	71. 65.
	57.5	2132.	2005.	1972.	922.	197.	203.	221.	146.	88. 83.
V	55.0	2190.	2046.	1969.	1147.	217.	204.	204.	143.	94. 89.
E	52.5	2129.	1972.	1805.	1316.	470.	227.	186.	123.	98. 95.
R	50.0	1971.	1777.	1690.	1384.	857.	329.	171.	103.	97. 98.
T	47.5	1799.	1667.	1670.	1493.	1210.	456.	174.	101.	101. 101.
I	45.0 <<	1759.	1670.	1699.	1578.	1253.	642.	270.	143.	121. 117.
C	43.0	1848.	1754.	1722.	1598.	1129.	762.	439.	246.	197. 175.
A	42.5	1882.	1779.	1723.	1588.	1115.	793.	481.	269.	217. 212.
L	40.0	2012.	1797.	1716.	1450.	998.	863.	691.	484.	433. 415.
	37.5	2041.	1757.	1579.	1221.	917.	912.	767.	631.	594. 593.
A	35.0	1937.	1642.	1326.	1041.	862.	863.	791.	694.	676. 667.
N	32.5	1704.	1355.	1086.	920.	833.	825.	802.	730.	705. 707.
G	30.0	1468.	1164.	968.	871.	829.	831.	814.	743.	720. 719.
L	27.5	1295.	1071.	945.	868.	865.	853.	794.	742.	727. 722.
E	25.0	1210.	1058.	959.	874.	857.	836.	800.	768.	748. 734.
	22.5	1213.	1092.	974.	876.	831.	833.	831.	822.	816. 802.
	20.0	1220.	1068.	1005.	891.	888.	880.	846.	857.	866. 866.
	17.5	1172.	1035.	952.	945.	939.	919.	885.	885.	882. 879.
	15.0	1127.	1048.	949.	935.	942.	925.	891.	871.	859. 857.
	12.5	1123.	1075.	1000.	914.	905.	883.	863.	863.	868. 869.
	10.0	1084.	1051.	997.	939.	906.	892.	883.	876.	880. 879.
	7.5	1055.	1028.	1006.	980.	943.	915.	905.	903.	905. 906.
	5.0	1049.	1029.	1017.	1002.	988.	977.	966.	945.	954. 934.
	2.5	1049.	1035.	1026.	1020.	1012.	1005.	998.	1000.	998. 998.
	0.0	1058.	1058.	1058.	1058.	1058.	1058.	1058.	1058.	1058. 1058.

CONE OF MAXIMUM CANDELA